ALL CORRESPONDENCE SHOULD BE
ADDRESS TO THE HEADMASTER
TELEPHONE: (852) 2711 5191
FAX: (852) 2761 1026
EMAIL: dbsadmin@dbs.edu.hk

DIOCESAN BOYS' SCHOOL
131 ARGYLE STREET,
KOWLOON,
HONG KONG
WEBSITE: www.dbs.edu.hk

SC/1509-002

4 September 2015

Second Water Test for Lead Content in School Premises

Dear Parents,

In response to the discovery of excess level of lead content in the water samples at the Michiko Miyakawa (IB) Building and the Yunni & Maxine Pao Auditorium, the School has installed an NSF (National Sanitation Foundation) filter 53 for the drinking water system on August 24 at the said buildings. Water tests were immediately conducted again by Pioneer Engineering Company, and assigned to the laboratory ALS Technichem (HK) Pty Ltd. The result received on September 1 showed that the lead level in the water (under 1 μg/L) is suitable for drinking.

Work Order HK1531787

Analytical Results

Sub-Matrix: **WATER**

			Client sample ID	DBS - IB01	DBS - IB02
			Client sampling date / time	[25-AUG-2015]	[25-AUG-2015]
Compound	CAS Number	LOR	Unit	HK1531787-001	HK1531787-002
EG: Metals and Major Cations					
EG020: Lead	7439-92-1	1	μg/L	<1	<1

The School held a meeting on September 1 with Kwan Shing Constuction Limited (the main contractor of the DBS-IB and Auditorium), Leading Consulting Engineers Ltd. (the M&E Consultant), and Cheung Lee Plumbing Engineering Co. Ltd (the water pipe installation sub-contractor), to carry out pipe work technical inspection and to propose necessary actions to solve the problem.

The School will continue to monitor the quality of water to safeguard the well-being of the members of the DBS Community.

Sincerely

R.K.Y. Cheng
Headmaster